Appendix A

Materials Degradation Modes and their Prediction

"He that will not apply new remedies must expect new evils; for time is a great innovator," from *Essays II Of Innovations,* Sir Francis Bacon (1561-1626)

"No sooner knew the reason, but they sought the remedy," from *As You Like It,* Shakespeare (1564-1616)

[Page intentionally blank]

Contents

Page

A.1 Introduction A-1
A.2 Materials of Construction A-2
A.3 Corrosion Basics A-7
A.4 Description of Degradation Modes and their Predictability in LWRs A-13
A.5 References A-46

List of Tables

Page

Table A.1 Compositions of Carbon & Low Alloy Steels Used in LWR Pressure Vessels & Piping (wt. %) 2

Table A. 2 Compositions of Some Stainless Steels Commonly Used in LWRs (wt. %)..... 3

Table A. 3 Compositions of Cast Stainless Steels used in LWRs (wt. %) 3

Table A. 4 Compositions of Nickel base alloys used in LWRs (wt. %) 5

Table A. 5 Expected Alloy/Degradation Mode Combinations for PWRs..... 6

List of Figures

Page

Figure A.1Pourbaix diagram for the iron- water system at 25°C, Activities of dissolved species of 10^{-6} gm-equivalents/L [7] 8

Figure A.2 Superimposition of Cr(OH)3 stability region onto the Pourbaix diagram for the iron-water system at 25oC and activities of dissolved species of 10-6 gm-equivalents/L. [4; adapted from 7] 9

Figure A.3. Oxidation and reduction reactions occurring on adjacent areas of surface [4] 10

Figure A.4 Schematic "Evans" diagram indicating the equilibration of the oxidation and reduction rates for the dissolution of zinc in 1N HCl solution, and the associated "corrosion current, (i_{corr})" and "corrosion potential, (E_{corr})". [4] 11

Figure A.5 Schematic oxidation current density vs. electrode potential diagrams, indicating, for the oxidation reactions, transitions from activation control, to onset of passivation, to oxide break down due to transpassivity or pitting. [4] 12

Figure A.6 Superposition of the reduction kinetics for dissolved oxygen on the metal oxidation rates from Figure A.5. In this case the reduction kinetics may be limited by the supply of oxygen to the reacting surface. [4] 13

Figure A.7 Corrosion of mild steel and solubility of magnetite at 300°C showing corrosion rate laws [9] 14

Figure A.8. Relationship between the corrosion rate of carbon and low alloy steels in various acidified boric acid solutions as a function of temperature. [15] 18

Figure A.9. Schematic of two-layer oxide structure on carbon steel in high temperature water. [16] 19

Figure A.10. Effect of temperature on the flow accelerated corrosion rate of carbon steel in deoxygenated ammoniated water. [20] 21

Figure A.11. Flow-accelerated corrosion data for condensate and moisturizer separator reheater drain systems in four BWR plants as a function of the local dissolved oxygen contents [Appendix B.10] 21

Figure A.12. Schematic of crevice in aerated solution, indicating the separation of the metal oxidation and oxygen reduction sites, and the consequent changes in pH and anionic concentrations 23

Figure A.13. Schematic of crevice formed at PWR steam generator tube/carbon steel tube-support, together with the phenomena that give rise to the localized corrosion. [23] 24

Figure A.14. Pitting, shown by the solid lines, and corrosion potential, (E_c), shown by the dashed lines, for Alloy 600 in water containing chloride anions as a function of temperature. [26, 27] 26

Figure A.15. Observed and theoretical crack propagation rate vs. crack tip strain rate relationships for sensitized 304 stainless steel in oxygenated water at 288°C. 29

Figure A.16. Conjoint material, stress and environment requirements for stress corrosion cracking [36] 29

Figure A.17. IGSCC in a 400 mm(16 ins.) diameter welded Type 304 pipe exposed to oxygenated water at 288oC. Note propagation adjacent to the weld heat affected zone, in a region associated with maximum grain boundary chromium depletion and weld residual tensile stress [37] 31

Figure A.18. Schematic of the crack enclave and the relevant phenomena associated with the slip oxidation mechanism of crack advance. 32

Figure A.19. Observed and predicted dependency between crack propagation rate for sensitized stainless steel and corrosion potential. [34,35] 32

Figure A.20. Predicted response of defected piping for defined changes in water chemistry in BWR plant. [35]..... 34

Figure A.21. Effect of oxygen and chloride concentration on the SCC of austenitic stainless steels in water 250-350oC, together with the oxygen/chloride ranges in BWR and PWR environments. [38] 35

Figure A.22. Regions in the PWR Primary Reactor Coolant System where PWSCC of nickel base alloys have been observed. 36

Figure A.23. Schematic diagram illustrating the locus of an axial PWSCC crack front in the Alloy 82/182 weld between dissimilar alloy carbon and stainless steel components..... 36

Figure A.24. Calculated change in crack depth in irradiated stainless steel as a function of fluence (e.g., time) due to specified changes in residual stress and degree of grain boundary sensitization. [see Appendix B.2]..... 38

Figure A.25. (a) Predicted [45] and observed [46] strain amplitude versus cycles to crack initiation relationships for unnotched carbon steel in 288EC, 8 ppm oxygenated water with strain applied at different rates. (b) Predicted [45] and observed [46,47] strain amplitude versus cycles to crack initiation relationships for unnotched carbon and low alloy steels in 288EC water, under the worst combination of material and environmental conditions. 42